



# KITCHEN HOOD FIRE SUPPRESSION SYSTEM PERMIT SUBMITTAL CHECKLIST FOR KENMORE & LAKE FOREST PARK

## Fire Marshal's Office

The following information is typically needed in order to submit an application for review. Depending on the scope of work, some items may not apply or may be combined. If you have a question on required items, please call the Fire Marshal's Office at 206-533-6565. Read each item carefully and provide all applicable information. **All site plans and civil drawings must be drawn to an engineering or architectural scale (e.g. 1" = 20' or 1/4" = 1').**

- |  |  |
|--|--|
| <ul style="list-style-type: none"><li><input type="checkbox"/> <b>Permit Application.</b> Indicate number of flow points in Project Description.</li><br/><li><input type="checkbox"/> <b>Submittal Fee:</b><br/>Commercial Cooking Heads:<br/>1 to 12 flow points           \$717.00<br/>More than 12                   \$956.00<br/>Other Fixed Locations       \$956.00</li><br/><li><input type="checkbox"/> <b>Kitchen hood must comply with UL300 standard</b></li></ul> | <ul style="list-style-type: none"><li><input type="checkbox"/> <b>Construction Drawings - three (3) copies</b> drawn to architectural scale. Drawings shall show:<ul style="list-style-type: none"><li>• Appliance layout with description and size of each appliance; hood layout showing exhaust duct location; piping runs, types and sizes; nozzle locations, heights and types; location of fusible links and manual activation.</li><li>• Copies of applicable sections from the manufacturer's design and installation manual for the system.</li><li>• Cylinder capacities, total flow point design, and pipe lengths.</li><li>• Location of gas shut off valve or electrical disconnect.</li><li>• Location of Class "K" fire extinguisher.</li></ul></li></ul> |
|--|--|

Fees effective 1/2023

**NOTE:** All submittal items must be legible. Number each page consecutively. For any additional information contact the Shoreline Fire Department at (206) 533-6565. No pencil drawings will be accepted.

**Headquarters: 17525 Aurora Avenue North, Shoreline, Washington 98133**

Telephone (206) 533-6565 | Fax (206) 546-5719 | [firepermits@shorelinefire.com](mailto:firepermits@shorelinefire.com)

1/2023